

ANNUAL RELEASE DETECTION TESTING RECORDKEEPING FORM

OKLAHOMA CORPORATION COMMISSION
 PETROLEUM STORAGE TANK DIVISION
 P.O. Box 52000
 Oklahoma City, OK 73152-2000

REQUIRED ANNUALLY

LOCATION OF TANK(S)

Facility Name or Company Site Identifier

Physical Address (PO Box NOT acceptable)

City, State & Zip

County

Inspection Date : ___ / ___ / ___

Facility Number: _____

Component Tested	Name of Tester	Pass/Fail	Needs Action? (Y, N, or N/A)	Action Taken To Correct Issue
Automatic tank gauge and other controllers: test alarm; verify system configuration; test battery backup.				
Probes and sensors: inspect for residual buildup; ensure floats move freely; ensure shaft is not damaged; ensure accessible cables are free of kinks and break; test external alarm operability and communication with controller.				
Automatic line leak detector: test to ensure device can detect 3 gallons per hour at 10 pounds per square inch (or equivalent) within one hour by simulating a leak.				
Vacuum pumps and pressure gauges: ensure proper communication with sensors and controller. (Refer to PEI 900)				
Hand-held electronic sampling equipment associated with groundwater and vapor monitoring: ensure proper operation.				

Other Components Tested:

Notes:

Technician Company : _____ **Technician Signature:** _____

Technician Name: _____

Keep this record for three years.